

ADDENDUM NUMBER [1]

Adams Street Lift Station Improvements

BID DATE: April 21, 2009

This Addendum forms a part of the Bidding Documents and modifies the original Project Manual and drawings for the **Adams Street Lift Station Improvements**. Receipt of this Addendum must be acknowledged in the space provided on the Bid Form at the time that the Bid is submitted. Failure to do so may subject the Bidder to disqualification.

The intent of this Addendum is to move the Bid Date to April 28th, 2009 at 1:00PM at the same advertised location; Office of the City Clerk, City Hall, 406 Ivinson Street, P.O. Box , Laramie, WY 82073, and to modify the Project manual as follows:

The following changes are hereby made to the Contract Documents:

Advertisement:

Replace the 1st paragraph of the Advertisement as follows:

Notice is hereby given that the City of Laramie, Wyoming, will receive sealed bids for the furnishing of all labor, materials, tools, appliances, transportation, and services necessary for:

Adams Street Lift Station

as called for in the Project Manual for the Adams Street Lift Station Improvements at the Office of the City Clerk, City Hall, 406 Ivinson Street, P.O. Box C, Laramie, Wyoming 82073, until 1:00 P.M. Local Time, on the 28st day of April, 2009, at which time the bids will be publicly opened and read aloud.

Specifications:

1. Section 02622 Plastic Pipe.
Add: 2.5. Location Aids
 - A. To be taped to top of all PVC pipe.
 1. Type: Solid.
 2. Gauge: 12 gauge.
 3. Coating: Insulated.
 4. Terminate trace wire in metering manhole per Owner's direction.

APPROVED BY _____ DATE _____
City Engineer

*** End of ADDENDUM ***