

FAX COVER SHEET

Total Pages 2

June 12, 2008

RETURN FAX CONFIRMATION REQUESTED

TO: ALL HOLDERS OF BIDDING AND CONTRACT DOCUMENTS

**RE: Inverness Water and Sanitation District
Inverness Lift Station No. 2
Addendum No. 2**


Holder:

Attached is ADDENDUM NO. 2 to the Inverness Lift Station No. 2 project

To verify that you have received this ADDENDUM NO. 2, we request that you FAX this acknowledgment to us at the FAX NO. 303-831-0290.

Thank you for your cooperation regarding this project.

Sincerely,

for 
Hsyi-Ming Jean, P.E.
Project Manager

HMJ/raf

Attachment

ACKNOWLEDGMENT OF RECEIPT:

Name: Sayros Mohamed

Company: Aslan Construction

Date: 6/12/08

ADDENDUM NO. 2
to the
Bidding and Contract Documents
for the Construction of
INVERNESS WATER AND SANITATION DISTRICT
INVERNESS LIFT STATION NO. 2

TO: ALL PLAN HOLDERS

DATE: June 12, 2008

The following changes, additions, and/or deletions are hereby made part of the Bidding and Contract Documents for the Inverness Lift Station No. 2 project for the Inverness Water and Sanitation District, Colorado.

The bidder shall acknowledge receipt of the Addendum on the bid form.

CHANGES TO SPECIFICATIONS

Addendum Number	Specification Section/Location	Addendum Item																
AD2-1	Section 08306-3, Article 4.01 (This change also affects callout of meter vault hatch on Sheet P4, Drawing 28 of 57)	<p>REPLACE Article 4.01 in its entirety with the following:</p> <p>4.01 HATCH SCHEDULE</p> <table border="1" data-bbox="740 861 1412 1276"> <thead> <tr> <th>LOCATION</th> <th>HATCH TYPE</th> <th>SIZE*</th> <th>QUANTITY</th> </tr> </thead> <tbody> <tr> <td>Electrical Room - 100</td> <td>A</td> <td>36" x 36"</td> <td>3</td> </tr> <tr> <td>Exterior - Lift Station</td> <td>B</td> <td>48" x 48"</td> <td>1</td> </tr> <tr> <td>Exterior - Meter Vault</td> <td>A</td> <td>30" x 48"</td> <td>1</td> </tr> </tbody> </table> <p>Note: Provide 1 1/2" drainage coupling and recessed hasp covered by a hinged lid flush with surface to accept a padlock.</p>	LOCATION	HATCH TYPE	SIZE*	QUANTITY	Electrical Room - 100	A	36" x 36"	3	Exterior - Lift Station	B	48" x 48"	1	Exterior - Meter Vault	A	30" x 48"	1
LOCATION	HATCH TYPE	SIZE*	QUANTITY															
Electrical Room - 100	A	36" x 36"	3															
Exterior - Lift Station	B	48" x 48"	1															
Exterior - Meter Vault	A	30" x 48"	1															
AD2-2	Section 16130	MODIFY the title in the footer of the specification to read "OUTLET, PULL, AND JUNCTION BOXES" in lieu of "EARTHWORK FOR STRUCTURES"																

CHANGES TO DRAWINGS

Addendum Number	Drawing Location	Addendum Item
AD2-3	Sheet No. MI, Drawing 32 of 57, Indirect Make-up Air Unit Performance Data Table	<p>CHANGE the following items in the table for MAU 208:</p> <ul style="list-style-type: none"> - CHANGE "INPUT MBH" to read "OUTPUT MBH" - CHANGE "HASTINGS SBD-215" to read "HASTINGS HRMU-100"

END OF ADDENDUM NO. 2